

Safety precautions to be strictly observed are marked with following symbols in the operating instructions:



The instruments must only be disposed of in the correct way!

## Operating Instructions

# Passive DC signal isolator SINEAX TI 816

CAMILLE BAUER

Camille Bauer LTD  
Aargauerstrasse 7  
CH-5610 Wohlen/Switzerland  
Phone +41 56 618 21 11  
Fax +41 56 618 35 35  
e-mail: info@camillebauer.com  
<http://www.camillebauer.com>



TI 816-5 Be 996 118-01 09.05

## Contents

1. Read first and then ...	1
2. Scope of supply	1
3. Brief description	1
4. Versions	1
5. Technical data	1
6. Mounting	1
7. Electrical connections	2
8. Commissioning and maintenance	2
9. Releasing the signal isolator	2
10. Dimensional drawings	2
11. Declaration of conformity	2

## 1. Read first and then ...



The proper and safe operation of the device assumes that the operating instructions is **read carefully** and the safety warnings given in the various Sections

### 6. Mounting

### 7. Electrical connections

are **observed**.

The device should only be handled by appropriately trained personnel who are familiar with it and authorised to work in electrical installations.

Unauthorized repair or alteration of the unit invalidates the warranty!

## 2. Scope of supply

### Signal isolator (Fig. 1)

1 ea. operating instructions (Fig. 2) in English, French, German



Fig. 1



Fig. 2

## 3. Brief description

The signal isolator SINEAX TI 816 serves to electrically insulate an analogue DC signal in the range 0...20 mA which depending on version is then converted to a current or voltage signal (0...20 mA or 0...10 V). It does **not** require a separate power supply.

The instrument fulfils all the important requirements and regulations concerning electromagnetic compatibility **EMC** and **Safety** (IEC 1010 resp. EN 61 010). It was developed and is manufactured and tested in strict accordance with the **quality assurance standard ISO 9001**.

## 4. Versions

There are two versions of the DC signal isolator SINEAX TI 816 available.

Description	Output signal A	Order code	Order No.
Passive <b>DC signal isolator</b> input signal E: 0...20 mA, with 1 isolation and transmission channel, in carrying rail housing N12	0...20 mA	816-5110	990 722
	0...10 V	816-5111	994 089

## 5. Technical data

### Input signal E →

DC current:	0...20 mA
Max. permissible current:	50 mA
Voltage limiter:	18 V ± 5% (with zener diode)
Voltage drop:	< 2.1 V (for 500 Ω burden)
Overshoot:	< 20 μA (typical 5 μA)

### Output signal A ↗

DC current or	0...20 mA or 0...10 V
DC voltage:	Approx. 30 mA <sup>1</sup>
Limit:	Approx. 15 V <sup>2</sup>
Max. burden:	600 Ω <sup>1</sup>
Internal resistance:	500 Ω <sup>2</sup>
Residual ripple:	< 20 mV ss
Time constant:	Approx. 5 ms

### Accuracy data

Error limits:	< ± 0,1% <sup>1</sup> (reference value 20 mA, linearity error included)
	< ± 0,2% <sup>2</sup> (reference value 10 V, linearity error included)

### Ambient conditions

Operating temperature::	-20 to + 65 °C
Storage temperature:	-40 to + 85 °C
Annual mean relative humidity:	≤ 75% Standard climatic rating
Seismic test:	5 g, < 200 Hz, 2 h in each of 3 directions
Shock test:	50 g, 10 shocks in each of 3 directions
Altitude:	2000 m max.
Indoor use statement	

## 6. Mounting

The SINEAX TI 816 isolator is suitable for mounting on two different types of standard rails:

- onto the G-type rail EN 50 035-G32
- or
- onto the top-hat rail EN 50 022-35x7.5.

<sup>1</sup> With current signal

<sup>2</sup> With voltage signal



Note "Ambient conditions" in Section "5. Technical data" when determining the place of installation!

Simply clip the signal isolator onto the carrying rail acc. to Fig. 3 or Fig. 4.




Fig. 3. Mounting onto the G-type rail.




Fig. 4. Mounting onto the top-hat rail.

## 7. Electrical connections

Easily accessible screw terminals are provided at the front of the signal isolator (Fig. 6) which accept wire gauges up to  $2.5 \text{ mm}^2$  (stranded wire) or  $4 \text{ mm}^2$  (non-stranded wire).



Note that, ...

... the data required to perform the electrical insulation task agree with the data on the nameplate of the SINEAX TI 816 ( $\ominus$  input signal and  $\oplus$  output signal, see Fig. 5)! ...

... in the case of isolators with **current** outputs  $0\ldots20 \text{ mA}$ , the total resistance of the external leads (receiver plus leads) **does not** exceed the max. burden of  **$600 \Omega$** ! See "output signal", section "5. Technical data"!

... in the case of isolators with a **voltage** output  $0\ldots10 \text{ V}$ , the external receiver connected across the output has a sufficiently **high** internal resistance  $R_{IA}$  in relation to the SINEAX TI 816 output impedance of  **$500 \Omega$** ! See "Output signal" in Section "5. Technical data"!

The error due to  $R_{IA}$  is:

$$F [\%] = \frac{500 [\Omega] \cdot 100}{R_{IA} [\Omega]}$$

... that input and output cables should be twisted pairs and run as far as possible away from heavy current cables!




Fig. 5. Example of a nameplate.

Connect the input and output leads E and A according to Fig. 6.



Fig. 6. Terminal allocation.

E = Input signal,  
A = Output signal.

## 8. Commissioning and maintenance

The device is in operation as soon as the input signal E is connected.

The signal isolator requires no maintenance.

## 9. Releasing the signal isolator

When dismantling the SINEAX TI 816 ...

... from **G rails** proceed according to Fig. 7. Firstly press the signal isolator upwards (manipulation 1) and tip it upwards at the same time (manipulation 2).

... from **top-hat rails** proceed according to Fig. 8. Tip the signal isolator upwards.




Fig. 7




Fig. 8

## 10. Dimensional drawings




Fig. 9. SINEAX TI 816 on G-type rail  
EN 50 035 – G 32.




Fig. 10. SINEAX TI 816 on top-hat rail  
EN 50 022 – 35x7.5.

## 11. Declaration of conformity



### EG - KONFORMITÄTSERKLÄRUNG DECLARATION OF CONFORMITY



Dokument-Nr./  
Document No.:

TI816.DOC

Hersteller/  
Manufacturer:

Camille Bauer AG  
Switzerland

Anschrift /  
Address:

Aargauerstrasse 7  
CH-5610 Wohlen

Produktbezeichnung/  
Product name:

Passiver DC- Signal trenner  
Passive DC signal isolator

Typ / Type:

SINEAX TI 816

Das bezeichnete Produkt stimmt mit den Vorschriften folgender Europäischer Richtlinien überein,  
nachgewiesen durch die Einhaltung folgender Normen:

The above mentioned product has been manufactured according to the regulations of the following  
European directives proven through compliance with the following standards:

Nr. / No.	Richtlinie / Directive
89/336/EWG	Elektromagnetische Verträglichkeit - EMV - Richtlinie Electromagnetic compatibility -EMC directive
89/336/EEC	

EMV / EMC	Fachgrundnorm / Generic Standard	Messverfahren / Measurement methods
Störaussendung / Emission	EN 50 081-2 : 1993	EN 55011 : 1992
Störfestigkeit / Immunity	EN 50 082-2 : 1994	IEC 1000-4-2 : 1995 IEC 1000-4-3 : 1998 IEC 1000-4-4 : 1995 IEC 1000-4-6 : 1996

Nr. / No.	Richtlinie / Directive
73/23/EWG	Elektrische Betriebsmittel zur Verwendung innerhalb bestimmter Spannungsgrenzen - Niederspannungsrichtlinie - CE-Kennzeichnung : 95
73/23/EEC	Electrical equipment for use within certain voltage limits - Low Voltage Directive - Attachment of CE mark : 95

EN/Norm/Standard	IEC/Norm/Standard
EN 61 010-1 : 1993	IEC 1010-1 : 1990 + A1 : 1992

Ort, Datum /  
Place, date:

Wohlen, den 4. November 1999

Unterschrift /

M.Ulrich

Signature:

Leiter Entwicklung

Diese Erklärung bescheinigt die Übereinstimmung mit den  
genannten Richtlinien, beinhaltet jedoch keine Zusicherung  
von Eigenschaften. Die Sicherheitshinweise der mitgelieferten  
Produktdokumentationen sind zu beachten.

This declaration certifies compliance with the above mentioned  
directives but does not include a property assurance.  
The safety notes given in the product documentations, which are  
part of the supply, must be observed.